

## 416/240 V. PANEL BOARD SCHEDULE

PANEL	: <u>LP</u>
CAPACITY	: 30 CIRCUITS CB 1,3 POLE
MAIN	: MCCB 3P 50AT IC $\geq 18kA$ 416/240 V.

LOCATION : ทางเข้าออฟฟิศ

MOUNTING : WALL MOUNTED

[illegible]

Lighting  $100 \text{ VA} \times 133 \text{ Unit} = 13,300 \text{ VA}$   
 $= 13,300 \text{ VA} / 3\text{P}$   
 $= 4,400 / 1\text{P}$

Power outlet  $180 \text{ V} \times 143 \text{ Unit} = 25,740 \text{ V}$   
 $= 25,740 \text{ VA} / 3 \text{ P}$   
 $= 8,580$

## ELECTRICAL LOAD SCHEDULE

---

### UNIT 14-2 UNOPS



## PROJECT

### ELECTRICAL LOAD SCHEDULE

LOCATION 208 BLDG

## INTERIOR DESIGNERS

APPROVED BY

REVISION:

[illegible]

### ELECTRICAL LOAD SCHEDULE

DRAW BY : AR.

DATE: \_\_\_\_\_

ID -103

**IMPORTANT : DO NOT SCALE THIS DRAWING**  
ALL DIMENSIONS SHOLUD BE CHECKED ON SITE