

Project Design:		DURRES HAMMAM	HAMAMI DURRES				
Ref to TS	Ref. to Albanian Technical Prices Manual/ Ref. Manualit te Cmimeve	WORK DESCRIPTION	PËRSHKRIMI I PUNIMIT	UNIT / NJËSIA	ESTIMATED QUANTITIES / SASIA	UNIT PRICE / ÇMIMI	AMOUNT / SHUMA
		INSTALLATION WORKS FOR MECHANICAL SYSTEM	PUNIME PER INSTALIMIN I SISTEMEVE MEKANIKE				
15.1		FIRE FIGHTING SIGNALIZATION	KARTELA SINJALIZIMI				
15.1.4	An	P.I Emergency Exit (AL-5107-B)	F.V Drejtim dalje emergjence (AL-5107-B)	copë	4.0		-
15.1.4	An	P.I Fire extinguisher with CO2 (AL-5206-B)	F.V Fikese zjarri me CO2 (AL-5206-B)	copë	1.0		-
15.1.4	An	P.I Fire extinguisher with dry powder (AL-5203-B)	F.V Fikese zjarri me pluhur (AL-5203-B)	copë	1.0		-
		Sum 01	SHUMA 01	Lekë/All			-
15.2		SANITARY WATER SUPPLY SYSTEM	SISTEMI I FURNIZIMIT ME UJI SANITAR				
		SANITARY WATER DISTRIBUTION NETWORK	RRJETI I SHPERNDARJES SE UJIT SANITAR				
15.2.1	An	P.I PEX/al pipe,DN 12 (Ø16 X 2.0) mm, insulated δ= 6mm	F.V Tubo PEX/al,DN 12 (Ø16 X 2.0) mm, i termoizoluar δ= 6mm	ml	22.0		-
15.2.1	An	P.I PEX/al pipe,DN 12 (Ø20 X 2.2) mm, insulated δ= 6mm	F.V Tuba PEX/al,DN 12 (Ø20 X 2.2) mm, i termoizoluar δ= 6mm	ml	15.0		-
15.2.2	An	P.I AL-PEX elbow Ø20x1/2 F, with press	F.V Bryla AL-PEX Ø20x1/2 F, me prese	copë	2.0		-
15.1.3	An	P.I Mounting and fixing elements. (metalik tape,nail, clamps)	F.V Elemente montimi dhe mberthimi. (Shirit metalik, gozhde, fasheta)	komplet	1.0		-
15.2.4	An	P.I Intersection mini valve for sanitary equipment	F.V Minivalvula nderprerese per pajisjet hidrosanitare	copë	4.0		-
		Sum 02	SHUMA 02	Lekë/All			-
15.3		WASTEWATER DISCHARGE SYSTEM	SISTEMI I SHKARKIMIT TE UJRAVE TE ZEZA				
		DISCHARGES IN THE WC's PLAN	SHKARKIMET NE PLANIMETRI TE WC-ve				
	2.1	P.I. Pipe ground excavations and transports	F.V Germim dhe transport dheu per kanalet e tubave	m³	39.0		-
	2.258/2	P.I. Gravel layer	F.V Shtrese cakulli	m³	18.0		-
15.2.6	An	P.I PP-R pipe , Ø50 X 6.9 mm PN 16	F.V Tub PP-R , Ø50 X 8,3 mm PN 16	ml	10.0		-
15.3.1	An	P.I Discharge pipe + fittings PP Ø 50	F.V Tuba shkarkimi + rakorderi PP Ø 50	ml	25.0		-
15.3.6	An	P.I Drainage Pipe Ø 160	F.V Tub drenazhimi Ø 160	ml	45.0		-
15.3.6	An	P.I Drainage Pipe Ø 200	F.V Tub drenazhimi Ø 200	ml	11.0		-
15.1.3	An	P.I Mounting and fixing elements.	F.V Elemente montimi dhe mberthimi.	komplet	1.0	-	-
15.3.7	An	P.I Control manhole R/C (40 x 40) cm, R/C cover 40x40cm	F.V Puseta Kontrolli B/A (40 x 40) cm, me kapak B/A 40x40cm, klasa C250 40 x 40	copë	4.0		-
15.3.8	An	P.I High density geotecstil	F.V Gjeotekstil me densitet te larte	€/m²	23.0		-
		Sum 03	SHUMA 03	Lekë/All			-
		TOTAL SUM A	SHUMA TOTALE A	Lekë/All			-
15.5		MACHINERY AND EQUIPMENT	MAKINERI E PAJISJE				
		FIRE FIGHTING SYSTEM	SISTEMI I MBROJTJES NGA ZJARRI				

15.5.3	An	S Dry powder fire extinguisher, for electric equipment protection type. Fire class 55A-233BC , Normal Capacity 5 kg , Weight 13.6 kg, Dimensions Ø 140 x 765 mm	F Fikse zjarri me pluhur . Tip bombel (e levizshem). Klasa e zjarrit A-B1-C, kapaciteti normal 6 kg, pesha 10 kg. Diametri 160mm, lartesia 560 mm.	copë	1.0		-
15.5.4	An	S CO2 fire extinguisher, for electric equipment protection type. Fire class 55A-233BC , Normal Capacity 5 kg , Weight 13.6 kg, Dimensions Ø 140 x 765 mm	F Fikse zjarri me CO2 destinacioni per mbrojtjen e paisjeve elektrike ne ndertes. Tip bombel (e levizshem). Klasa e zjarrit 55A-233BC, kapaciteti normal 5 kg, pesha 13.6 kg. Diametri 140mm, lartesia 765 mm.	copë	1.0		-
		Sum 04	SHUMA 04	Lekë/All			-
		SANITARY WATER SUPPLY SYSTEM	SISTEMI I FURNIZIMIT ME UJI SANITAR				
15.5.11	An	S. Supplay Technical characteristics: -Electric power : 550 W, -Current : 2.8 A, -Voltage : F 1 x 200x240V, 50Hz -Flow : 3 m³ / h -Head: 27 mkH2O -Connection: Ø 1" / PN 10, -Completed with the necessary fittings (pressure reducer, intersection valve, non-return valve, etc.)	F.Pompe furnizimi me uje karakteristikat teknike: -Fuqia e instaluar : 550 W, -Intensiteti i rrymës : 2.8 A, -Tensioni i dhenë :F 1 x 200x240V, 50Hz -Prurja: 3 m³ / h -Prevalenca: 27 mkH2O -Lidhjet: Ø 1" / PN 10, -Kompletuar me rakorderite e nevojshme (reduktor presioni, saracineska, valvol moskthimi etj.)	copë	1.0		-
		Sum 04	SHUMA 04	Lekë/All			-
		HVAC SYSTEM	SISTEMI HVAC				
15.5.8	An	S. Radiant pannel for floor heating system with auto temperature regulation	F. Panel radiant per ngrohje nga dysHEMEJA me vete rregullim temperature	m²	51.0		-
		Sum 04	SHUMA 04	Lekë/All			-
		TOTAL SUM B	SHUMA TOTALE B	Lekë/All			-
							.
		TOTAL SUM A + B	SHUMA TOTALE A + B	Lekë/All			-