



September 12, 2022

**BID BULLETIN NO. 3
ITB-069-PHL-2022
Supply and Delivery of 300 units of Generator Sets**

Dear Prospective Bidders,

We are pleased to share with you our response to the query from interested bidders. Please see the below table for your reference.

| Inquiry | | UNDP Response |
|---------|--|--|
| 1 | About the surge output, it is normally 110% of the rated output. i.e. 6.5KW. Please kindly advise. | A surge output of 6.5kW substantially complies with the “at least 7.5kW” published specification. The deviation is 1kW thus 1kW/7.5kW is a 13% deviation or less than 25% from the specification and this can still satisfy the function required. |
| 2 | As per the manufacturer's feedback, the Duplex is 120V, not 240V. Please kindly advise. | For the Philippine setting, we are using a standard voltage of 220-240V. Thus, for safety purposes and operational compatibility, bidders should strictly comply this requirement. |

Please be informed that the **deadline** for submitting proposals has been extended from September 13, 2022, 2:00 AM Eastern Time to **September 23, 2022, 2:00 AM Eastern Time**.

Please be guided accordingly.

All the best,
UNDP Procurement