



September 12, 2022

BID BULLETIN NO. 4
ITB-069-PHL-2022
Supply and Delivery of 300 units of Generator Sets

Dear Prospective Bidders,

We are pleased to share with you our response to the query from interested bidders. Please see the below table for your reference.

Inquiry		UNDP Response
1	Amendment to Technical Specifications for generator sets (Reference to Bid Bulletin 3, Item #1)	Minimum surge output requirement is revised to 6.5kW instead of 7.5kW. However, the rated output offered must strictly comply with requirements in the Invitation to Bid (ITB).
2	Will the performance bank guarantee or performance bond be submitted only after project has been awarded?	Yes, performance security will only be required from the winning firm after contract award.

Please be guided accordingly.

All the best,
UNDP Procurement