

Rehabilitation of Ninety-Six (96)
Public Schools in Lebanon

LRPS-2023-9182373

Q&A
Annex 1

BIDDERS QUESTIONS - Technical related
All Schools Related Technical Questions:

Lot 4

1. Concerning the generators to be relocated in Lot 4/ School 142/ Antelias Secondary Public School and Lot 5 School 216/ Yahshoush Mixed Intermediate Public School:
 - a. Kindly provide us with the old and new location of each generator.
 - b. Specify the location of the existing MDB and totalizing panel at each school to check if new cabling is required as well.
 - c. in BOQ- LOT 4, sheet 150-Optional, line 1529, the cell cannot be priced due to protection

- a. The generators and diesel tanks are currently located in the basement floors. The contractor shall relocate them in a safe and secured area in the open playgrounds (both schools).
- b. The MDBs are located in the electrical room in basement floors (refer to DWG)
- c. Refer to attached adjusted File

Lots 4 and 11

2. in lots 4 and 11, all the optional BOQs mention in the mechanical division line 1724 item 6.11 an item description Heating system with no further description

Kindly note that only one heating system is included in the tender documents of these 2 lots with all related descriptions (329-Al Warhaniyeh Mixed Intermediate Public School)

3. in BOQ 589- Al Bireh Mixed Public School, All Division 5 cannot be priced (protected sheet)

Refer to attached adjusted sheet