

Questions & Answers

REQUEST FOR QUOTATION: No. RFQ/HCR/SYR/24/23

THE SUPPLY, DELIVERY, AND INSTALLATION OF INTERIOR BACKUP LIGHTING SYSTEM IN THREE BUILDINGS AT IBN KHALDOUN PSYCHIATRIC HOSPITAL IN ALEPPO

QUOTATION TO BE RECEIVED BY: 22nd May 2024 – 15:00 hrs, Syria Local Time

- 1- When visiting the site, the hospital management asked the potential bidders to extend electrical cables only and exclusively through additional external plastic ducts. Will the price of these extra ducts be charged to the item (copper tape)? In the same context, one of the buildings has false ceilings, and there are ducts from previous extensions. Is it possible to benefit from them (extend inside them)?

All copper wire extension work should be within the plastic ducts already in the buildings or under the false ceilings. New ducts need only be installed in small spaces with minimal quantities.

The End