

Annex D - The Technical Offer Form
Request for Quotation: No. RFQ/HCR/SYR/24/23

Provision and Installation of Interior Backup Lighting System in Three Buildings at Ibn Khaldoun Psychiatric Hospital in Aleppo

The Minimum technical specifications for required alternative lighting system							
#	Item	Specifications	Notes	Quantity	Unit	YES/NO	Comment
1	Tubular battery	12 V, 200 Ah, not less that 800 cycles at 70% discharge (or equivalent), newly produced not before than 6 months. 12 months warranty at least	Brand new battery (please specify the BRAND & MODEL)	9	piece		
2	DC Charger	Battery charger, fully compatible with batteries specs (Voltage, Current, and capacity of the batteries). Auto stop when battery is fully charged	Well known brand (please specify the BRAND & MODEL)	9	piece		
3	1/2 meter LED strip	High quality LED strip, 12V, white color, with frosted cover, and easy-to-fix on wall aluminium chassis. Two color wires for electric connection (positive & negative)	High-quality, low heat emission, and long lifespan (please specify the BRAND & MODEL)	256	piece		
4	1/4 meter LED strip	High quality LED strip, 12V, white color, with frosted cover, and easy-to-fix on wall aluminium chassis. Two color wires for electric connection (positive & negative)	High-quality, low heat emission, and long lifespan (please specify the BRAND & MODEL)	61	piece		
5	DC Circuit Breaker	40 A, dual breaker, DC	High-quality, well known brand, and long lifespan	9	piece		
6	Relay 50 A	Electromagnetic On/Off switch relay.	High-quality, well known brand, and long lifespan	9	piece		
7	Metal box equipped with a lock	The size should be suitable for the battery dimensions. It should be a wall-mounted metal box with mesh for proper ventilation	The box should have an anti-corrosion coating	9	piece		
8	Deep discharge protection circuit	Prevent deep discharge of the battery	High-quality, and long lifespan	9	piece		
9	On/Off Switches	Electric switches for turning the LED strips on and off	High-quality, and long lifespan	85	piece		
10	Copper wires	Pure copper, flexible, 2x1mm, stranded with 32 strands of 0.2mm each, compliant with Syrian National Standard 638	(please specify the BRAND & MODEL)	1500	meter		
MANDATORY DOCUMENTS TO BE SUBMITTED							
1	Valid Business/Commercial Registration Certificate						
2	Valid Commercial Bank account						
3	Name of the company should match the bank account						
4	Financial Statements/Audit reports of the last two years 2023-2022						
5	Vendor registration form for Commercial Suppliers						
6	Acknowledgement and acceptance of UNHCR's General Conditions of Contracts for the Provision of Goods and/or Services Rev. July 2018						
7	Acknowledgement and acceptance of UN Supplier Code of Conduct						
8	Declaration of Eligibility filled, dully signed, and stamped						
9	Customs Declaration of the required items (If applicable).						

By signing on this document, which I am duly authorized to sign for, I confirm that I have read and understood the technical requirements and this is also to confirm that our company is experienced and capable of providing the required goods and/or services specified in this Request for Quotation.

Signature:

Full Name:

Position Title:

Date and Place Signed:

STAMP OF THE COMPANY