

Annex B Detailed Specification Requirement and Quantity

No.	Technical specification	Qty
#10	Fire extinguishers Type: CO2 Capacity (kg.): 4.5 kg. / 10lbs Rating: 70BC Discharge Time (sec.): 16 Shooting Range (M.): 4.5 Working Pressure (Bar): 174 Test Pressure (Bar): 250 Cylinder Height (mm.): 490 Overall Height (mm.): 600 Overall Diameter (mm.): 152 Gross Weight (kg.): 15.00 Cylinder Thickness (mm.): 5 Shell Material: Carbon Steel CK45 Class of Fire: B & E User Guide: One- or two-pages user guide in Khmer/ Video guide in Khmer (optional) Warranty: At least 12 months The fire extinguishers must be certified from ministry of interior (MOI) of Cambodia. The proof documents or proof certificates from MOI must submit along the bid submission.	1,650
#20	Transport Fee of fire extinguishers to 128 locations. The distribution list attached.	128
#30	Rack shelves 4levels for Provincial Health Department (PHD) Size: L2000 x W600 x H2000MM Quantity: 50 Rack materials: steel Steel thickness or Capacity of loading: 300kgs/level, 4levels Steel frame (ideal for storing materials) Color: Frame Blue Color: Beam Orange Feature: Easy to assemble and disassemble Warranty: at least 1 year	50
#40	Rack shelves 3 levels for Operational Health District Offices (OD) Size: L2000 x W600 x H2000MM Quantity: 103 Rack materials: steel Steel thickness or Capacity of loading: 300kgs/level, 3levels Steel frame (ideal for storing materials) Color: Frame Blue Color: Beam Orange Feature: Easy to assemble and disassemble Warranty: at least 1 year	103

#50	Transportation and installation fee of rack shelves (4-3 levels) to 128 locations. The distribution lost attached.	128
-----	--	-----

