

LITB:2024-9191865

Annex (B)

Items Specifications: -

No	Qty	Specifications
00010 U422320	3	<p>GRP water tank capacity 45 M3 manufactured and design of (Hot Press Moulded GRP Sectional Water Storage Tanks) shall be to the quality standard requirements of (BS EN ISO 9001) and shall comply with (BS EN 13280:2001) glassfibre reinforced plastic cisterns for cold water storage.</p> <p>2 Process Requirements</p> <p>2.1 Cisterns shall be manufactured by the Hot Press Moulded method, glass reinforced plastic, moulded at temperatures up to 150°C using polyester resins which conform to ISO 472, UV stabilised and 'E' glassfibre reinforcement, colour grey (RAL 7004).</p> <p>2.2 The cistern design shall incorporate 1x1m pillow panels to the walls of cisterns with provision for flat panels for connections and fittings. Purpose made cover panels 1x1m and 1x0.5m flat panels positioned to give free draining channels.</p> <p>2.3 Base panels available internally flanged (IFB) with 1x1m flat panels, fasteners internal (stainless steel Grade 1.4401), or externally flanged (EFB) with 1x1m flat panels and one pillow sump panel, fasteners external (Galvanised). Alternatively stainless steel fasteners throughout can be requested.</p> <p>2.4 All surfaces of the panels shall be smooth and crevice free to provide hygienic finish and be dimensionally accurate with sharply defined profiles.</p> <p>2.5 Float valve chambers can be provided with central hinged or lift off lockable ABS lid, with options of 180mm, 300mm and 500mm depth, where appropriate provision for Type AB air gap in compliance with BS EN 13077:2008.</p> <p>2.6 Man access 600mm diameter screwed, hinged or lift off lockable ABS lid available.</p> <p>2.7 All tanks deeper than 1.5m shall be fitted to client requirements with internal stainless or GRP and external standard duty aluminium access ladders: to BS 4211 with hooped safety cage.</p> <p>2.8 Handrail is offered as an option and should be considered to meet particular contract needs.</p>

		<p>3 Steelwork</p> <p>3.1 Panels to be rigidly supported by a combination of stainless steel tie rods internally and galvanised box section externally.</p> <p>3.2 Steelwork designed to EN 10088-3:1995. Internal stainless steel 1.4401 (316/A4) grade and external mild steel galvanised to BSEN ISO 1461:2009. Cisterns to incorporate external wall bracing on depths 1.5m and greater and tie rods 2m and greater.</p> <p>4.2 Panels to be insulated within a profiled face covering the maximum surface area and to be encapsulated with an external weather skin made from ultraviolet stabilised material providing protection against weathering.</p> <p>4.3 Connections to be site fitted on flat insulated panels, and all holes shall be sealed with a recessed plastic section from the outer surface of the insulation skin to the cistern panel.</p> <p>5 Foundation</p> <p>5.1 All cisterns to be installed on either flat continuous foundation, close centre beams, pier walls or bearer beams conforming to manufacturer's specification of flatness and deflection and to be provided by the client. Refer to BSTL 1693-004 to BSTL-1693-012.</p> <p>6 Partitions</p> <p>6.1 Where partitions are required, they will be full height using standard panels. Each compartment will be capable of supporting water on either side with one side empty.</p> <p>6.2 Where tank walls require external reinforcement, then partition walls shall be similarly reinforced in grade 316 stainless steel.</p> <p>7 Connections</p> <p>7.1 All connections supplied to be site installed.</p> <p>GRP SECTIONAL TANK STANDARD SPECIFICATION</p> <p>7.2 Connections 54mm and below, plain/BSP threaded, 67mm and above flanged to PN16 unless otherwise stated.</p> <p>7.3 Standard flanged connections as Balmoral 'BSTL' range, spool piece with internal support flange, external stub flange with loose galvanised ring.</p> <p>7.4 All connections to be installed in accordance with WRAS/current water byelaws. Tank manufacturer has WRAS approval for compliance with BS EN 13077 installations.</p> <p>9 Commissioning and Testing</p> <p>9.1 Testing shall be carried out on completion of installation by a mechanical contractor and should be completed within ten working days of assembly.</p>
--	--	--

		This shall include the final setting of float valves level switches and any other connection which requi
00020 SL017082	5	Water tank hard plastic Plastic Tank 5000 Lit
00030 U422320	336	water tank 500 lit
00040 U422320	52	Water tank Plastic Tank 10000 Lit
00050 SL005614	50	Water tank, plastic, 10000 litre