


Suppliers Questions & UNICEF Answers		
Question no.	Question	UNICEF Answer
1	Cable avg distance for the 4 locations	This needs to be measured at UNICEF premises by each supplier taking into consideration each location distance to the electricity room
2	Maximum Delivery period	6-8 weeks max including installation
3	Evaluation process (for example the weight of key parameters)	The evaluation is based on the offered components of the entire generator system, capacity of the offered generator that supplies full power load to the premises, the offered price, if all parts are genuine of the same brand (not assembled from different brands), Certificate of origin should be provided, supplier certificate confirming that all generator parts are original of the same brand.
4	LTA holders have better chance? and how	Please refer to the above mentioned evaluation criteria
5	Is factory acceptance test (FAT) mandatory in this RFQ	Yes „the FAT certificate is required + testing and comissioning upon installation is required by the supplier
6	Is it accepted to submit two options in our offer	Yes „,indeed
7	Please determine the warranty period	Minimum 2 years is acceptable, and 3 years are preferred
8	According to the delivery and installation period, please confirm that it is determined by the supplier in his offer	Delivery period should be indicated in the supplier's offer
9	Please confirm that it required submitting bid bond with supplier's offer, and if it required please providing us with its details and templates	Bid Bond is not required for this procurement.. Warranty certificate and a bank guarantee is required. Pleaese refer to below mentioned details:
10	Please confirm that it required performance bond and maintenance bond in this RFQ	<p>WARRANTY</p> <p>1.The supplier shall provide no less than a 2-year warranty of the generator and entire connection and tanks. The supplier agrees to provide free of charge all parts and labour necessary to repair any defects that may arise during the first and second year and replace any defected spare parts during the warranty period and to maintain the generator for 2 years. The supplier shall warrant that the product supplied to UNICEF shall equal or higher than the published specifications.</p> <p>The warranty letter shall indicate the warranty start date from the date of Substantial Completion of installation and commissioning.</p>
11	Please confirm if bank guarantee is required	Bank Guarantee: The contractor is required to submit a bank guarantee at 5% of the final purchase order value (The actual executed quantities value), against the defects liability period valid for 12 months.
12	Please provide us with the building's drawings in order to determine the accurate cable distance	The supplier is required to understake site inspection and the required measurement. UNICEF cannot provide the drawings of the premises
13	Is it accepted to use the existing cable trays and existing ducts in the installation works	This can be accepted only for location A
14	<p>According to the "Location A" (current location in P1), can we consider the roof top for the existing old generators as an option to install a new generator as per the below picture</p> 	No ..There will be new offices built on top of location A
15	Is it necessary to build foundation concrete base for all locations or we can use rubber under the generator	UNICEF is responsible for the concrete base civil works „this is not within the supplier's scope...