

Questions and Answers

RFQ-HCR-SYR-2024-59

Provision of rehabilitation services for primary health centers in Damascus and rural Damascus

	Question	UNHCR Response
1	Will the centres remain operational during the rehabilitation works?	Yes, the centres will remain operational. Bidders should plan their work accordingly.
2	in the ToR, it is mentioned that "Samples of each item must be submitted to the supervision team for approval before installation" Is it possible that the committees to reject items?	for the awarded supplier, samples are required to ensure compliance with the technical specifications detailed in their tender proposal. Samples also may require selecting appropriate colours, model etc.
3	In the Location 5, Saeeda Zeinab, Item 1.7.4 "Provision and installation of base cabinets", please provide the dimension of the cabinets	The height does not exceed 80cm, and the depth is up to 60cm.
4	In the Location 5, Saeeda Zeinab , Item, Providing and installing lithium batteries 48v 200ah with accessories. Please confirm the accurate capacity requirement as there's a discrepancy between the Bill of Quantities (BoQ) and Terms of Reference (ToR)." (200 or 300 ah)	300 Ah Annex B "Bill of Quantities (BOQ)" and Annex E "Financial Offer Form" have been revised as necessary.
5	In location 4: Maarabani , <ul style="list-style-type: none"> • Question 1, Provision and installation a solar power panels with accessories. Please confirm the number of solar panels • Question 2, Provision and installation lithium batteries 50 KV with accessories. Please confirm the accurate capacity requirement as there's a discrepancy between the Bill of Quantities (BoQ) and Terms of Reference (ToR)." 50 or 30 	Question 1: 10 solar panels. Question 2: 30 KV Annex B "Bill of Quantities (BOQ)" and Annex E "Financial Offer Form" have been revised as necessary.

6	In the Location 3, Jdaidet Artouz , Providing and installing lithium batteries 48v 200ah with accessories. Please confirm the accurate capacity requirement as there's a discrepancy between the Bill of Quantities (BoQ) and Terms of Reference (ToR)." (200 or 300 ah)	200 Ah Annex A3 Location3 ToR Jdaidet Artouz has been revised as necessary.
---	--	---