

**UNHCR**United Nations High Commissioner for Refugees
Haut Commissariat des Nations Unies pour les réfugiés

Questions and Answers

RFQ-HCR-SYR-2024-56

Provision of Rehabilitation Services in Sweida Governorate.

	Question	UNHCR Response
1	<p>Lot#1: item no. 9, Supply and Apply window Frame Catcher System: it is mentioned that the requested quantity is 100 the MoU is “No.”</p> <p>Do you mean 100 units regardless of the length of the cable?</p> <p>Please clarify!</p>	<p>Correct, the paragraph is estimated by one, and one includes: the cable regardless of its length + six fixing clips + two fixing rings + two fixing bolts.</p> <p>صحيح , تقدر الفقرة بالواحدة, وتشمل الواحدة : الكبل بغض النظر عن طوله + ستة مشبك تثبيت + اثنتان حلقة تثبيت + اثنتان وتد تثبيت</p>
2	<p>Lot#1: item no. 13, Supply and Apply A 0.8 mm thick SRF adhesive film.</p> <ul style="list-style-type: none">The requested quantity is 24 which is not covered all the windows and doors in the building.Please confirm if the request includes the removal of the existing SRF.	<p>The work requires Supply and Apply film for windows that do not have film only.</p> <p>العمل يتطلب تقديم و تركيب الفيلم للنوافذ التي ليس لها فيلم فقط</p>
3	<p>Lot#1: In the ToR, there is a request for “a layer of sandbags covers the surface of the Generator Enclosure and surrounds the fuel tanks to provide protection”.</p> <p>This request is not indicated in the BoQ. Please confirm the quantity required, as well as the required thickness of the layer and the dimensions of the sandbags.</p>	<p>The BoQ will be amended. A layer of sandbags is placed over the generator room, also surrounds and over the diesel tanks. In addition, surrounds the fuel tanks in the new store, with a quantity of 6 cubic meters.</p> <p>ينفذ طبقة من اكياس الرمل فوق غرفة المولدة و فوق وحوالي خزانات المازوت بالاضافة الى اكياس رمل حوالي بيدونات البزين الاحتياطية في المستودع الجديد بكمية 6 متر مكعب</p>
4	<p>Lot#1: In the ToR, Parking Area, the highest of the Steel Shade is 2.5 m. while on the side of the Sidewalk, the height of the wall requested is 2 meters.</p> <p>Please confirm if the 0.5m gap will remain open</p>	<p>A metal mesh (2 cm openings) is installed in the opening above the sheet metal wall on the neighbors' side along the length of the hangar, with a quantity of 13 square meters. The mesh is fixed on all sides by welding.</p> <p>ينفذ في الفتحة فوق جدار الصاج من جهة الجيران شبك معدني (فتحات قياس 2 سم) على طول الهنغار بكمية ١٣ متر مربع ويثبت الشبك من كل الجهات باللحام الكهربائي</p>