



UNHCR

United Nations High Commissioner for Refugees
Haut Commissariat des Nations Unies pour les réfugiés

Questions and Answers

RFQ-HCR-SYR-2024-57

Supply, delivery and installation of solar powered system kits in Dara governorate.

	Question	UNHCR Response
1	We observed that there are damaged window frames and air conditioners on the roof of the building. Could you please clarify whether these will be removed to prepare the work site, or if the responsibility for their removal falls to the supplier	The supplier will not be responsible for removing the damaged window frames and air conditioners on the roof of the building
2	The necessity of including a circuit breaker between the inverter and batteries, with a minimum rating of 125 amps.	Yes, its required as per the Annex A