

CLARIFICATIONS SUPPLY OF SOLAR KITS

03.07.2018

Q1. Your clarifications on Date June 25: Q9 battery is 12V, 120AH/100H. And the original request for the qty for the system is 120pcs.

Your clarification on Date June 27: Q2.5 table mentioned battery is 12V/800Ah, qty of battery is 8pcs

Which is correct?

In the ItB we have not mentioned the quantity of the Batteries but a complete 200WP Solar Power System. The bidder should be in a position to identify the quantity of batteries required for such a system as different brands may have different specs and capacities and therefore may require different quantities of batteries.

Q2. Your clarification on Date June 25: Q10 cable is 50 rolls 2x6mm² cable, each roll contain 50 meters, total 2500 meter for each system

Your clarification on Date June 27: Q2.5 table: cable is 50 rolls but each roll is 8 meter, total 400 meter for each system.

Which is correct?

The length of the cable should be: 6mm²x50 rolls of 8 Meters.